

# Madera Unified School District

#### March 3, 2023

### Addendum No.1 Bid No 022123-Asphalt Resurface & Repairs at Multiple Sites

#### NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No. 022123-Asphalt Resurface & Repair at Multiple Sites with a due date of March 8, 2023 @ 10:00:00 am March 15, 2023 @ 2:00:00 pm

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Added Job Walk-There will be a job walk for this project on Wednesday March 8, 2023 starting at 8:00 am at Ripperdan then Eastin Arcola, then to Parkwood and ending at Pershing (please refer to the Notice to Bidders for site locations.

This Job Walk has been added due to the conflict of information posted on the Builders Exchanges vs. the Information posted on the District Website. If you attended the 1<sup>st</sup> job walk held on March 1, 2023 you DO NOT need to attend.

Questions/Clarifications:

General Questions:

1. Who is responsible for any sprinkler work? **District** 

#### **Ripperdan:**

- 1. Do concrete pads need to be removed? No, pads remain.
- 2. Extend the planter to grass –ls a concrete border needed for the planter perimeter? **YES**
- 3. Basketball Courts, extend asphalt to the fence
- 4. Gate post, MUSD will provide a sleeve for the contractor to install

#### Eastin-Arcola:

- 1. Does the contractor need to replace the drainage or have water drain to the grass? Contractor to extend drainage pipe and raise the box. Water can drain to the grass
- 2. ADA Path? None

Todd Lile Superintendent Board of Trustees Ruben Mendoza, Clerk Lucy Salazar, President

Nadeem Ahmad

Israel Cortes Gladys A. Diebert Joetta Fleak Ray G. Seibert





# **Madera Unified** School District

- 3. Will the center pole will need to be removed and replaced after grading? Yes, remove and replace at grade
- 4. Do the concrete pad by the building and concrete strip in the center need to be removed? **YES**
- 5. MUSD will provide Christy boxes if needed

# Parkwood:

- 1. What kind of paint should be used for the restriping? (Oil base with glass beads) Striping shall be installed per CA spec. waterborne paint, applied at a minimum thickness of 15 mils. Type I or II glass beads shall be applied immediately after application, minimum rate of 5lbs per gallon of paint used.
- 2. Will the reflectors need to be replaced? Yes, replace all reflectors with new Stimsonite Model 88AY Reflectors. See attached photo for color choice.

# Pershing:

- 1. Does the concrete around the tetherball poles need to be removed and replaced? Yes, remove only. Do not replace.
- 2. Will the 12 volleyball sleeves need to be removed and replaced? Yes, remove all sleeves. Do not replace.

Signature

Todd Lile Superintendent



Board of Trustees Ruben Mendoza, Clerk Nadeem Ahmad

Israel Cortes Gladys A. Diebert

Joetta Fleak Ray G. Seibert

