



April 15, 2021

**Addendum No.2 Bid No.033021-Carpet Removal and Installation at Multiple School Sites**

**PLEASE NOTE CHANGE IN BID TURN IN DATE**

**NOTICE TO ALL VENDORS:**

This Addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for **Bid No.033021-Carpet Removal and Installation at Multiple School Sites**, with a due date of April ~~15~~, **21**, 2021 @ 10:01 am

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.  
Questions/Clarifications:

**Substitutions**

The District has received and reviewed several product substitutions please see attached specifications of substitutions submitted and which have been **accepted** and **rejected**.

Please note the Mannington Carthage Legacy is not an accepted substitution. -it does not meet or exceed the specified Patcraft product in the following categories:  
Dye method, gauge, pile thickness tufted yarn weight. The specified also has a protective treatment.

Date\_\_\_\_\_

Signature\_\_\_\_\_