

MADERA UNIFIED SCHOOL DISTRICT 1902 Howard Road Madera CA 93637 (559) 675-4500 (559) 675-1186 Fax www.madera.k12.ca.us

**Board of Trustees:** <u>President</u>: Al Galvez

<u>Clerk</u>: Ed McIntyre

<u>Trustees</u>: Ricardo Arredondo Brent Fernandes Ruben Mendoza Ray G. Seibert Maria Velarde-Garcia

INTERIM SUPERINTENDENT: Todd Lile April 18, 2017

Addendum No. 1 Bid No.040417-Demolition of Existing Structure at Madison Elementary School

## NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for BID No.040417 with a due date of April 27, 2017 @ 10:00. All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

## **Clarifications**

Refer to Document 00020-Notice Inviting Bids Should read the following: Valid class <del>C8</del> or C21 Contractor's License.

Refer to: General, Description, Quality Assurance Utility Services, Contractor shall notify utility companies or local authorities. The District will be responsible to notify PG & E to terminate gas and electrical service at distribution point, the District will take care of the water service.

## **Questions**

- 1. Are the steps in front of the building part of the demolition? Yes, Contractor to demo steps in front of the building
- 2. Grading Grade to sidewalk level towards grass area.
- Is it ok to use dirt from grade as Fill Dirt?
  Yes, Ok to use dirt from grading as part of the fill. Fill dirt to be clean. Demo needs to be down to the dirt.
- Export of soil, who is responsible?
  No export of soil, District will provide dump truck for excess soil
- 5. Fence to be pulled down Contractor to pull down fence along Olive Ave. to the light control box and is responsible to hall away. District will install new fence
- 6. Where is electrical to be dropped? All electrical to be dropped at poll

7. What is to happen to miscellaneous items in building? All items in building are to be disposed of.

Signature \_\_\_\_\_

Date\_\_\_\_\_