



April 10, 2019

Addendum No. 1
Bid No.040319-Asphalt Resurface & Repair Projects
at Multiple School Sites

NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above entitled specifications for Madera Unified School District for Bid No.040319 Asphalt Resurface & Repair Projects at Multiple School Sites

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Bid Due date of April 18,2019 @:
Bid Section No.1 Monroe-9:00 am
Bid Section No.2 Pershing-9:15 am
Bid Section No.3 Howard -9:30am
Bid Section No.4 Madison-9:45 am

Questions/Clarifications:

Clarifications:

"Prior to any crack sealing remove any organic or loose material from the base of the depression buy use of an asphalt crack heat lance. If the depression is grease or oil-stained, wash the surface with an asphalt cleaner to remove the oil and grease. For cracks 3/4" or wider add a 1-inch layer of cold-mix asphalt patch to the bottom of the low area. Choose a cold-mix patching material that has added binding agents to promote adhesion to the existing asphalt (submit cold-mix specs for approval). Tamp cold-mix asphalt patching material down until it is compacted tightly to the base of the depression. Add 1-inch layers of cold-mix asphalt patching material, tamping each layer until you build the final patch up the surface of the existing driveway."

Monroe Elementary School:
No Curbs are to be painted
Stripe "as is"
Seal around Wheel Stops

**MADERA UNIFIED
SCHOOL DISTRICT**
1902 Howard Road
Madera CA 93637
(559) 675-4500
(559) 675-1186 Fax
www.madera.k12.ca.us

Board of Trustees:
President:
Ray G. Seibert

Clerk:
Ruben Mendoza

Trustees:
Ricardo Arredondo
Brent Fernandes
Joetta Fleck
Ed McIntyre
Lucy Salazar

SUPERINTENDENT:
Todd Lile

Addendum No.1-con't:

Pershing Elementary School:

Restripe Basketball and Tetherball White

Restripe Volleyball Yellow

*****see attached updated map*****

Howard K-8:

*****see attached updated map*****

Madison Elementary School:

Basic striping and crosswalk to ADA Code

*****see attached updated map*****

Signature: _____

Date: _____