



August 6, 2019

Addendum No. 1 Bid No.070119A  
Martin Luther King Middle School Water Controller Project

**NOTICE TO ALL VENDORS:**

This Addendum is attached to and made a part of the above entitled specifications for Madera Unified School District for Bid No.070119A- Martin Luther King Middle School Water Controller Project with a Bid Due date of August 14, 2019 @ 10:01 a.m.

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Questions/Clarifications:

1. Can existing wiring be used for the 2-wire system? **There is no two wire system. The controllers are conventional wired.**
2. Valve Locations? **District will be responsible for locating all valve locations**
3. Is it ok to pour concrete over existing concrete? **Yes**
4. Where is the contractor's laydown storage location? **The contractor can use the space where the back entrance is to the cafeteria.**
5. Who is responsible for pulling wiring to the location? **The District is responsible for the electrical wiring to the Christie box by the pump enclosure. The contractor will pick up the wiring from the Christie box to the new pump package electrical panel. The District will pull the wire once the location of the panel is known so enough wire is pulled to reach the panel.**

**MADERA UNIFIED  
SCHOOL DISTRICT**  
1902 Howard Road  
Madera CA 93637  
(559) 675-4500  
(559) 675-1186 Fax  
[www.madera.k12.ca.us](http://www.madera.k12.ca.us)

**Board of Trustees:**  
President:  
Ray G. Seibert

Clerk:  
Ruben Mendoza

Trustees:  
Ricardo Arredondo  
Brent Fernandes  
Joetta Fleck  
Ed McIntyre  
Lucy Salazar

**SUPERINTENDENT:**  
**Todd Lile**

Date \_\_\_\_\_

Signature \_\_\_\_\_