



Madera Unified School District

1902 Howard Road, Madera, CA 93637
559.675.4500
Fax: 559.675.1186
www.madera.k12.ca.us

March 25, 2025

Addendum No.1 Bid No.031125-Thomas Jefferson MS Roofing Project

NOTICE TO ALL VENDORS:

This addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No.031125-Thomas Jefferson MS Roofing Project, with a Bid Turn in date of March 27, 2025 @ 10:00 am.

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.

Clarification/Questions:

Do you have Asbestos and lead environmental report for this roof?

No asbestos report since we are not removing the existing roofing.

Clarifications:

- Add to Section 011100 Summary of Work Section 1.3, D: Install new rubber dura blocks at all locations as needed. Existing dura blocks that are in good condition may be reused.
- Add to Section Section 011100 Summary of Work Section 1.3, D: see the attached site map and photos.
 - Install a 22 gauge galvanized sheet metal cap over the ridge line and fasten on each side. Classrooms 33-36
 - Change building "P", remove the original building P as shown and change to the addendum building P.
 - Repair blisters in the walkway roof as noted along the brick wall and shown on the site map.
See attached

Signature: _____

Date: _____


Superintendent

Ray G. Siebert, President

Ruben Mendoza, Clerk
Nadeem Ahmad

Israel Cortes
Gladys A. Diebert

Joetta Fleak
Lucy Salazar



Addendum 1 -
Install a 22 ga galvanized sheet metal cap
over the ridge line and fasten on each side.
Classrooms 33-36

Addendum 1 -
This building is not included.
Building P moved to upper top
right side of the site photo

Addendum 1 -
Repair all blisters in this roof area
as discussed at the pre bid meeting

Addendum 1 -
Add Change to Building P
Add to Scope of Work

