



March 25, 2020

Addendum No.1-Bid No.031720-Tile Work at Various School Sites

NOTICE TO ALL VENDORS:

This Addendum is attached to and made a part of the above-entitled specifications for Madera Unified School District for Bid No.031720-Tile Work at Various School Sites with a Bid Turn in date of April 2, 2020 @ 10:01 a.m.

All changes and/or clarifications will appear in bold type and deletions will be struck out within a sentence.
Questions/Clarifications:

New Bid Turn In Process..

Changes to Bid Turn In

Due to the current and changing situation and to continue with work that is needed at our School Sites we have implemented changes as to how we are going to handle the Bid Turn In Process.

The District encourages vendors to submit bids in advance by mail and we will accept emailed bid packets.

If you email the packet, it will only be accepted if it is sent to susanharautuneian@maderausd.org and it must be received no later than the date and time listed.

In order to comply with CDC guidelines and applicable Government requirements, no public opening will take place. Instead, MUSD staff will open all bids once inside the building.

MUSD staff will collect all the bids. No public opening will take place at that time.

MUSD staff will open all bids once inside the building. Staff will recap the Bids and post the Bid Tally along with each contractors Bid Form on the District Website. Once the Bid is Awarded, the Awarded bidder will be required to submit all the original copies to the Purchasing Department.

Clarifications:

1. The Eastin-Arcola portion of the project has been eliminated
2. Flores Gym: No tile to be installed on exposed concrete floor or restroom floors with antiskid paint.
3. Flores Gym coach's office restroom: Remove all tile in the shower including the floor. Waterproof the floor before new floor tile is installed.
4. Flores Gym South shower area: Remove the concrete water stop at the entrance to the shower. Install new floor tile in its place

MADERA UNIFIED SCHOOL DISTRICT
1902 Howard Road, Madera, California 93637
(559) 675-4500
FAX: (559) 675-1186
www.madera.k12.ca.us



Board of Trustees:
Ruben Mendoza, President
Brent Fernandes, Clerk
Trustees:
Ricardo Arredondo, Joetta Fleak,
Ed McIntyre, Lucy Salazar, Ray G. Seibert
Superintendent:
Todd Lile

Questions:

1. Building 800, do we remove the tile floor under the water fountain?
Yes, remove and replace the tile with specified mat tile.
2. Is the contractor responsible for providing and installing thresholds?
No. The District will provide and install the thresholds.

Clarifications

Missing from Bid Packet-form 00400-Contractor's Certificate Regarding Workers Compensation
See attached form to be submitted as part of the Bid Documents

Date _____

Signature _____

DOCUMENT 00400
**CONTRACTOR'S CERTIFICATE REGARDING
WORKERS' COMPENSATION**

I am aware of the provisions of Section 3700 of the Labor Code which require every employer to be insured against liability for workers' compensation or to undertake self-insurance in accordance with the provisions of that code, and I will comply with such provisions before commencing the performance of the work of this Contract.

Name of Bidder _____

Signature _____

Name _____

Title _____

Dated _____